

Madrid, 12<sup>nd</sup> of March, 2021

We hereby confirm that the following anchors in the mentioned sizes and types used according to the relevant assessment, are in full compliance with guideline

VdS CEA 4001:2021-01(07) *Guidelines for sprinklers systems. Planning and installation*

for applications of water extinguishing systems on concrete elements:

<b>THE</b> screw anchor	6 to 18	ETA 20/0494
<b>MTP, MTP-G, MTP-X</b> wedge anchor	M8 to M20	ETA 12/0397
<b>MTP-A4</b> wedge anchor	M8 to M16	ETA 15/0145
<b>HEHO, HECLO, HEHC, HEA4</b> drop in anchor	M8 to M20	ETA 14/0068
<b>SLPT, SLPC</b> heavy duty anchor	M8 to M20	ETA 18/1108

Cecilio López Hombrados  
Head of structural testing unit  
Instituto de Ciencias de la Construcción Eduardo Torroja. EOTA member  
Serrano Galvache 4  
28033 Madrid. Spain